



COMMONWEALTH of VIRGINIA

Karen Shelton, MD
State Health Commissioner

DEPARTMENT OF HEALTH
**OFFICE OF DRINKING
WATER**
Richmond Field Office

Madison Building
109 Governor St., 6th
Floor Richmond, VA
23219
Phone: 804-864-7409
Fax: 804-864-7520

SUBJECT: LOUISA COUNTY
Water - Mamma Leone
PWSID: 2109031

February 18, 2025

Mr. Salvatore Anile
Owner, Mamma Leone
4418 Davis Highway
Louisa, VA 23093

Dear Mr. Anile,

Enclosed please find Waterworks Operation Permit No. 2109031 with Operation Permit Conditions dated February 18 2025 issued by the Commonwealth of Virginia Department of Health, Office of Drinking Water. This permit is your authorization from the State Health Commissioner to operate The Mamma Leone waterworks located in Louisa County in accordance with the *Waterworks Regulations*. This permit is not transferable. This permit does not suspend, minimize, or otherwise alter this owner's obligation to comply with applicable federal, state, or local laws and regulations or permits.

The waterworks has a design capacity of the existing restaurant with a maximum occupancy of 50 people. This limit is based on the maximum capacity of the system and shall not be exceeded.

As provided by Rule 2A:2 of the Supreme Court of Virginia, you have thirty (30) days from the date you actually received this permit or the date it was mailed to you, whichever occurred first, within which to appeal this permit by filing a notice of appeal in accordance with the Rules of the Supreme Court of Virginia with the State Health Commissioner. In the event that this permit is served on you by mail, three days are added to that period.

We look forward to your cooperation in the maintenance and operation of this public waterworks.

Sincerely,


Azhar Mirza
District Engineer
Office of Drinking Water

cc: Louisa County Dept of Health, attn: Environmental Health Manager
Christian Goodwin, Louisa County Administator



Virginia Department of Health
Office of Drinking Water

Waterworks Operation Permit

Salvatore Anile is granted permission to operate the Mamma Leone waterworks, an unclassified transient noncommunity waterworks located in Louisa County, in accordance with Title 32.1 of the *Code of Virginia* and 12VAC5-590-10 *et seq.* of the *Virginia Waterworks Regulations*. The waterworks has a capacity to serve an existing restaurant with an occupancy of 50 people. The owner understands the operation of the waterworks shall be in compliance with Part II of the *Virginia Waterworks Regulations* titled "Operation Regulations for Waterworks." This permit does not suspend, minimize, or otherwise alter the owner's obligation to comply with other applicable federal, state, or local laws and regulations or permits. Notify the Office of Drinking Water immediately upon change of ownership. The State Health Commissioner may revoke this permit at any time upon determining that the waterworks can no longer be depended upon to furnish pure water, or meets other criteria in *Code of Virginia* § 32.1-174. The waterworks may not be changed, altered, or improved without prior approval from the Office of Drinking Water, consistent with the requirements in 12VAC5-590-190 *et seq.* of the *Virginia Waterworks Regulations*.

All required sampling must be completed in accordance with the *Virginia Waterworks Regulations* and associated sampling plans.

Inventory: One bored well, one 119-gallon bladder tank, and distribution system

Operating Conditions: The waterworks shall provide sufficient distribution storage and pumping capacity to meet peak hourly flow demand. The waterworks is permitted for a capacity limited to the existing restaurant with an occupancy of 50 people until information on the well yields and pump capacities is provided

PERMIT NO.: 2109031

EFFECTIVE DATE: February 18, 2025

APPROVED

James Reynolds, PE, Engineering Field Director, Richmond Field Office
for the State Health Commissioner pursuant to VA Code § 2.2-604