



COMMONWEALTH of VIRGINIA

DEPARTMENT OF HEALTH

OFFICE OF DRINKING WATER

Dr. Karen Shelton, MD
State Health Commissioner

Richmond Field Office

Madison Building
109 Governor Street
6th Floor
Richmond, VA 23219
Phone: 804-864-7409
Fax: 804-864-7520

System Sanitary Survey Report

February 5, 2025

To: Mr. Curt Heidel, Manager
924 South Lake Shore Drive
Louisa, Virginia 23093

SUBJECT: Louisa County
Waterworks: Ridge Utilities, Inc.
PWSID: 2109075

Survey Date: January 29, 2025

Next Survey Due By: January 29, 2028

Present at Survey:

Name	Organization
Azhar N. Mirza, District Engineer	Virginia Department of Health
Curt Heidel, Manager	Ridge Utilities, Inc.
George Allen Kail, Waterworks Operator	Ridge Utilities, Inc.
Jeff Garrett, Waterworks Operator	Ridge Utilities, Inc.

As a result of the sanitary survey noted above, the Office of Drinking Water offers the following comments. Should you have questions or desire to discuss our findings, please contact me at (804) 664-4404 or Azhar.Mirza@vdh.virginia.gov

SIGNIFICANT DEFICIENCIES:

There were no significant deficiencies at the time of this inspection.

MINOR DEFICIENCIES:

The Virginia Waterworks Regulations require your waterworks to complete the following actions.

Section	Required Actions
Sources/Wells	Wells 1, 1A, 6, 7, 8, & 9 need to replace pressure gages in the well discharge lines.

Please visit our web site at <http://www.vdh.virginia.gov/ODW/>. There you will find helpful information on water sampling and testing, operator licensing and training, consumer education, project funding and **many other topics, as well as, links to other key websites and Virginia's Waterworks Regulations.**

Survey By:



Azhar N. Mirza
District Engineer

Attachment: System Sanitary Survey Report

cc: Curt Heidel, Manager, cheidel@brshores.com
Louisa Co. Health Dept., attn: Environmental Health Manager
Christian Goodwin, Louisa County Administrator – info@louisa.org