



## COMMONWEALTH of VIRGINIA

B. Cameron Webb, MD, JD  
State Health Commissioner

Department of Health  
P O BOX 2448  
RICHMOND, VA 23218

TTY 7-1-1 OR  
1-800-828-1120

September 28, 2026

Via Electronic Mail: [mlynn@ses-company.com](mailto:mlynn@ses-company.com)

SES Mid Atlantic Utilities, Inc.  
c/o Mr. Mike Lynn  
SESMAU Jerdone Island  
9251 Industrial Court, Suite 101  
Manassas, VA 20109

**RE: SESMA Utilities Waterworks (Louisa County)  
Public Water System Identification No. VA2109265  
Termination of Consent Order**

Dear Mr. Lynn:

The State Health Commissioner, acting on behalf of the State Board of Health, entered into an Order by Consent (Order) with SES Mid Atlantic Utilities, Inc. (SESMA), which became effective on August 27, 2024, to resolve certain violations of the Public Water Supplies Law and applicable regulations at the SESMA Utilities Waterworks in Louisa County.

The Order requires that SESMA take certain specific actions to provide and maintain conditions throughout the waterworks to assure a high degree of capability and reliability, as required by 12VAC5-590-360.A of the Waterworks Regulations, and pay a required civil penalty of \$1,232.

SESMA has completed the requirements of the Order. This includes completion of action items on the approved Corrective Action Plan and Schedule by providing additional source capacity with the drilling of a second well, completing an Asset Management Plan and a Waterworks Business Operation Plan, installing remote monitoring of water tank levels and operational status of pumping equipment, and adhering to interim action requirements related to water hauling during the most critical periods. SESMA also paid the required civil penalty.

Section D.12.a. of the Order states that the State Health Commissioner or his designee may terminate the Order upon SESMA completing all the requirements of the Order.

The State Health Commissioner has delegated authority to ODW's field directors to terminate Orders by Consent pursuant to the terms of the order. Pursuant to that delegation of

Mr. Lynn  
September 28, 2026  
Page 2 of 2

authority, and upon my finding that SESMA has completed all the requirements of the Order, the Order is hereby terminated.

Termination of the Order does not relieve SESMA from the obligation to comply with any statute, regulation, permit condition, other order, certificate, certification, standard, or other applicable requirement.

Thank you for your cooperation in resolving this matter. If you need additional information about this letter, please contact Laura Taylor, Environmental Health Compliance Specialist, at [laura.taylor1@vdh.virginia.gov](mailto:laura.taylor1@vdh.virginia.gov).

Sincerely,



James Reynolds, P.E.  
Field Direction  
Richmond Field Office

cc: Grant E. Kronenberg, Director of Division of Compliance, Enforcement, and Policy, VDH-ODW Central Office; [Grant.Kronenberg@vdh.virginia.gov](mailto:Grant.Kronenberg@vdh.virginia.gov)  
Athena Van Lear, Enforcement Coordinator, VDH-ODW Central Office;  
[Athena.VanLear@vdh.virginia.gov](mailto:Athena.VanLear@vdh.virginia.gov)  
Laura Taylor, Environmental Health Compliance Specialist, Richmond Field Office;  
[laura.taylor1@vdh.virginia.gov](mailto:laura.taylor1@vdh.virginia.gov)  
Jack "Jack" McClelland, Environmental Health Manager, VDH Blue Ridge Health District; [john.mcclelland@vdh.virginia.gov](mailto:john.mcclelland@vdh.virginia.gov)  
Christian Goodwin, County Administrator, Louisa County; [cgoodwin@louisacounty.gov](mailto:cgoodwin@louisacounty.gov)