COMMONWEALTH of VIRGINIA

DEPARTMENT OF HEALTH

OFFICE OF DRINKING WATER

Richmond Field Office

B. Cameron Webb, MD, JD
State Health Commissioner

Madison Building
109 Governor St., 7th Floor
Richmond, VA 23219
Phone: 804-864-7409
Fax: 804-864-7520

OFFICIAL ELECTRONIC COMMUNICATION – NO HARD COPY TO FOLLOW

October 27, 2026

SUBJECT: LOUISA COUNTY
Waterwork: Christopher Run Campground
PWSID: 2109130

Dear Mr. Craun:

We have reviewed the PEC for Christopher Run Campground (2109130). The PEC states that Wells 2, 5, and 6 will operate alternately, but the proposed source capacity is based on the combined pump capacity. We have the following comments:

1. Do the controls and the piping allow multiple wells to be in operation when the water demand is high, like in summer months?
2. Please submit piping calculations when multiple wells are in operation simultaneously.
3. Add sequence of putting multiple wells in operation when the demand is high.

Please revise the PEC accordingly and submit. If you have any questions, please call me at 804-664-4404.

Sincerely,
Azhar N. Mirza
Azhar N. Mirza
District Engineer

ec: Mr. Samuel Kelley, manager@christopherruncampground.com
Mr. Mike Craun, Engineer, ode@olddominionengineering.com
Christian Goodwin, Louisa County Administrator – info@louisa.org

T:\ECSO-Serverdata\DISTRICT\PD18\05-Project Review\PER Review\PER Comments\2109130 Christopher -Commentletter_2026-10-27.Docx