



COMMONWEALTH of VIRGINIA

DEPARTMENT OF HEALTH

OFFICE OF DRINKING WATER Richmond Field Office

Karen Shelton, MD
State Health Commissioner

Madison Building
109 Governor St., 6th Floor
Richmond, VA 23219
Phone: 804-864-7409
Fax: 804-864-7520

SUBJECT: LOUISA COUNTY
Water- Louisa Little League Well 1
PWSID: 2109005

May 1, 2025

Louisa Little League
C/O Mr. Harvard Loudin
405 Louisa Avenue
Mineral, Virginia 23117

Dear Mr. Loudin:

This notice is to inform you that in accordance with the Commonwealth of Virginia *Waterworks Regulations* 12VAC5-590-430, the following determination has been made with respect to the direct influence of surface water of the groundwater sources to serve the subject waterworks.

Well No. 1 has been determined to be a groundwater source and is NOT under the direct influence of surface water.

Since the above referenced source have been determined to be groundwater sources, no further action on your part is required with respect to the filtration requirements of the USEPA Surface Water Treatment Rule or the *Waterworks Regulations*.

Please feel free to call me at (804) 664-4404 should you have any concerns or additional questions.

Sincerely,

Azhar N. Mirza
District Engineer

ANM:anm

cc: Louisa Co. Health Dept., attn: Environmental Health Manager
Lisa Harvey, lharvey@loudin.net
Christian Goodwin, Louisa County Administrator — info@louisa.org

T:\ECSO-Serverdata\DISTRICT\PD18\15-GWUDISW02_Determination Notices\Louisa Little League Doc