



# COMMONWEALTH of VIRGINIA

DEPARTMENT OF HEALTH

## OFFICE OF DRINKING WATER

Richmond Field Office

Karen Shelton, MD  
State Health Commissioner

Madison Building  
109 Governor St., 6th Floor  
Richmond, VA 23219  
Phone: 804-864-7409  
Fax: 804-864-7520

SUBJECT: LOUISA COUNTY  
Water- 183 Pleasant Landing Well 1  
PWSID: 2109005

March 5, 2025

Mr. Tres Bedell  
618 Sunset Loop  
Mineral, Virginia 23117

Dear Mr. Bedell:

This notice is to inform you that in accordance with the Commonwealth of Virginia *Waterworks Regulations* 12VAC5-590-430, the following determination has been made with respect to the direct influence of surface water of the groundwater sources to serve the subject waterworks.

**Well No. 1 has been determined to be a groundwater source and is NOT under the direct influence of surface water.**

Since the above referenced source have been determined to be groundwater sources, no further action on your part is required with respect to the filtration requirements of the USEPA Surface Water Treatment Rule or the *Waterworks Regulations*.

Please feel free to call me at (804) 664-4404 should you have any concerns or additional questions.

Sincerely,

Azhar N. Mirza  
District Engineer

ANM:ann

cc: Louisa Co. Health Dept., attn: Environmental Health Manager  
Robby Estabrooke, Co-owner — rob.estabrooke@yahoo.com  
Christian Goodwin, Louisa County Administrator — info@louisa.org

T:\ECSO-Serverdata\DISTRICT\PD18\15-GWUDISW\02\_Determination Notices\183 Pleasant Landing Doc